

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1622 / DLMA / 2023-24

Dated: 24/06/2023

It is certified that an inspection team headed by Laxman Surb, D.C.(Name of Officers with designation) from D.C. (D.L.M.A. Meerut)

(Name of Department/ Office) inspected the MIET Public School, 6th Mile Stone, Mawana Road, Meerut. U.P. on 24/06/23 and found that the MIET Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of 05 Years.

Signature with Seal 24/06/23Name : Laxman Surb, D.C. जि.बे.शि.अ. / सदस्य-सचिव
सुव. शाला साक्षरता कार्यक्रम
मेरठ।Designation : D.C.

Name & Address of the Office / Department :

Vikas Bhawan, Collectorate
Meerut-

To

The Manager

MIET PUBLIC SCHOOL

6th Mile Stone, Mawana Road,

Meerut. U.P.

For MIET PUBLIC SCHOOL

Principal

For MIET PUBLIC SCHOOL

24/06/23
Manager



ENVIRO TECH SERVICES PVT. LTD.

An Analytical Laboratory

(A GOVERNMENT APPROVED LAB)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

email : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461



TEST REPORT

TEST REPORT NO.: ETS/2122-5/05/2025 ULRNO.TC153902500021225F DATE OF REPORT: 21.05.2025

WATER SAMPLE ANALYSIS REPORT


Name And Address of Customer : MIET PUBLIC SCHOOL
6TH MILESTONE MAWANA ROAD, MEERUT

Date of Sample Received : 18.05.2025
Analysis Start Date : 18.05.2025
Analysis End Date : 21.05.2025
Sample ID No : 2122-5
Sampling Done By : BY CUSTOMER
Sampling Description : DRINKING WATER
Sampling Location : FROM R.O.
Sampling Method : IS 3025 (Part-1)
Sample Quantity : 2.0+0.5 Ltr
Packing Condition : SEALED
Packed In : P.V.C. AND GLASS BOTTLE

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012)		Test Method
				Desirable	Permissible	
PHYSICAL & CHEMICAL PARAMETERS;						
1	pH	...	7.19	6.5 - 8.5	No Relaxation	APHA 4500-H+
2	Turbidity	NTU	<1.0	1	5	APHA 2130-B
3	Total Dissolved Solids,(TDS)	mg/L	120.2	500	2000	APHA 2540-C
4	Conductivity	µs/cm	178.0	No Relaxation	No Relaxation	APHA 2510-B
5	Free Chlorine (Residual)	mg/L	<0.02	0.2	1	APHA 4500:(Cl)-B
6	Fluoride,(F)	mg/L	<0.01	1	1.5	APHA 4500:(F-)-D
7	Total Alkalinity,(CaCO3)	mg/L	39.0	200	600	APHA 2320-B
8	Total Hardness,(CaCO ₃)	mg/L	54.0	200	600	APHA 2340-C
9	Calcium,(Ca)	mg/L	9.8	75	200	APHA 3500:(Ca)-B
10	Chloride,(Cl)	mg/L	8.2	250	1000	APHA 4500:(Cl-)-B
11	Magnesium,(Mg)	mg/L	7.0	30	100	APHA 3500:(Mg)-B
12	Nitrate,(NO ₃)	mg/L	<0.1	45	No Relaxation	APHA 4500:(NO ₃ -)-B
13	Sulphate,(SO ₄)	mg/L	9.4	200	400	APHA 4500:(SO ₄)-E
HEAVY METALS;-						
14	Iron,(Fe)	mg/L	<0.05	1.0	No Relaxation	APHA-3120B

*****End of Test Report*****

For Enviro Tech Services Pvt. Ltd.



Format No ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

AUTHORIZED SIGNATORY
(Quality Manager)



Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.

Principal

Manager



ENVIRO TECH SERVICES PVT. LTD.



(A GOVERNMENT APPROVED LAB)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

email : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461



TEST REPORT


TEST REPORT NO.: ETS/2122-5/05/2025

DATE OF REPORT: 21.05.2025

WATER SAMPLE ANALYSIS REPORT

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012)	Test Method
MICROBIOLOGICAL PARAMETER;					
15	Escherichia coli	Per 100mL	Absent	Shall Not Be Detectable	IS15185

*****End of Test Report*****



No ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

AUTHORIZED SIGNATORY



For MIET PUBLIC SCHOOL

Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.

For MIET PUBLIC SCHOOL

Manager